

We, ABB Limited

Of, Oldends Lane Stonehouse Gloucestershire England GL10 3TA

Declare under our own responsibility that the product: **AZ30 Remote Terminal Box** to which this declaration relates is in conformity with the following standards:

Directive 2006/95/EC (LVD)

Harmonised Standard Used: EN61010-1:2010

Directive 2004/108/EC (EMC)

Harmonised Standard Used: EN 61326-1:2006

Directive 94/9/EC (ATEX) and IECEx

Harmonised Standard Used:

IEC 60079-0:2011 EN 60079-1:2007 EN 60079-31:2009

Provisions of the Directive fulfilled by the Equipment. Equipment Group:-



II 2GD Ex d IIB+H₂ T6 Gb (Ta -20°C TO + 70°C) Ex tb IIIC T85°C Db (Ta -20°C TO + 70°C) IP66

Name, notified body number and address of the Notified Body:-

Baseefa Ltd, Number 1180, of:- Rockhead Business Park, Staden Lane, Buxton, Derbyshire SK17 9RZ

Number of the type examination certificate:-

Baseefa12ATEX0077X - last supplement issued 16 April 2012 IECEx BAS 12.0049X - last supplement issued 23 April 2012

When installed and operated according to the supplied instructions.

2.2.15

Date of Issue

Signature Julian Dobson- Quality Manager