



中国国家强制性产品认证证书

证书编号：2014010304724380

委托人名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产者（制造商）名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、规格、型号

软启动器

PSTX30***70, PSTX37***70, PSTX45***70, PSTX60***70, PSTX72***70,
PSTX85***70, PSTX105***70; 详细参数及型号解释见附件

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2018年03月13日 有效期至：2019年09月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2014年09月25日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010304724380

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

PRODUCT NAME, MODEL AND SPECIFICATION

Softstarter

PSTX30***70, PSTX37***70, PSTX45***70, PSTX60***70, PSTX72***70, PSTX85***70, PSTX105***70; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.13,2018

Valid until: Sep.25,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.25,2014

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2014010304724380

纸 号: 1910850

PSTX30***70, PSTX37***70, PSTX45***70,
 PSTX60***70, PSTX72***70, PSTX85***70, PSTX105***70
 额定绝缘电压(Ui): 600V(PSXT***-600), 690V(PSXT***-690);
 约定发热电流(Ith): PSTX30:30A, PSTX37:37A, PSTX45:45A, PSTX60:60A, PSTX72:72A,
 PSTX85:85A, PSTX105:106A ;
 额定工作电压(Ue): 208-550V AC(PSXT***-600), 208-690V AC(PSXT***-690);
 额定工作电流(Ie): PSTX30:30A, PSTX37:37A,
 PSTX45:45A, PSTX60:60A, PSTX72:72A,
 PSTX85:85A, PSTX105:106A;
 使用类别: AC-53a;
 极数: 3P
 额定功率(Pe):

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2014010304724380

纸 号: 1910850

Type	Ic (A)	Power(KW)			
		220-230V	380-400V	500V	690V
PSTX30-600-70	30	7.5	15	18.5	-
PSTX37-600-70	37	9	18.5	22	-
PSTX45-600-70	45	12.5	22	25	-
PSTX60-600-70	60	15	30	37	-
PSTX72-600-70	72	18.5	37	45	-
PSTX85-600-70	85	22	45	55	-
PSTX105-600-70	106	30	55	75	-
PSTX30-690-70	30	7.5	15	18.5	25
PSTX37-690-70	37	9	18.5	22	30
PSTX45-690-70	45	12.5	22	25	37
PSTX60-690-70	60	15	30	37	55
PSTX72-690-70	72	18.5	37	45	59
PSTX85-690-70	85	22	45	55	75
PSTX105-690-70	106	30	55	75	90

型号解释:

Typekey for Softstarter in the PSTX-series

PSTX ***-6**-70

1 2 3 4

1 = Softstarter, name of series

2 = Current rating, I_c: 30=30A, 37=37A, 45=45A, 60=60A, 72=72A, 85=85A, 105=106A

3 = Operational voltage, U_c: 00 = 208-550V AC, 90 = 208-690V AC

4 = Control supply voltage, U_s: 70 = 100 - 250V AC

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心