

CERTIFICATE OF COMPLIANCE

Certificate Number 20170221-E190233
Report Reference E190233 - 19980331
Issue Date 2017-FEBRUARY-21

Issued to: BRISTOL INC
1100 BUCKINGHAM ST
WATERTOWN CT 06795-6602

This is to certify that representative samples of PROGRAMMABLE CONTROLLERS FOR USE IN HAZARDOUS LOCATIONS
Hart Device Interface Board Part No. 392930-01-3 for use in Class I, Division 2, Groups A, B, C and D hazardous locations.


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA 12.12.01-2011, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
UL 508, Industrial Control Equipment
C22.2 No. 213-M1987, Non-incendive Control Equipment for Use in Class I Division 2 Hazardous Locations.
C22.2 Nos. 142-M1987, Process Control Equipment

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

